



ADDENDUM NO. 1

August 27, 2026

Owner: Village of Pleasantville

Project: Walnut Street Tank Improvements

This ADDENDUM forms a part of the Contract Documents and modifies the original specifications and drawings as noted below. The Bidder must acknowledge receipt of this ADDENDUM in the space provided in the Bid Schedule Form and shall also submit a signed copy with his bid. Failure to acknowledge this ADDENDUM and submit a signed copy may subject the Bidder to disqualification.

This addendum covers revisions and/or clarifications to the bidding documents as follows:

We have received Requests for Information (RFI) on this project. Those questions and responses are below:

Q: *What are the dimensions of the tank (gallons and height)?*

A: Approximately 155,000 gallons and 116 feet tall to the overflow.

Q: *What is the maximum amount of "out-of-service" time permitted?*

A: The tank is currently OUT of service until this project is completed.

Q: *What are the expected dates of commencement and substantial completion?*

A: The Owner expects to award the bid on September 10 then execute a construction contract a couple weeks later followed by 60 days to complete the project. Please read the bid item description for scope of work. This is finishing a previous project, so the painting scope of the project is limited.

This document serves as Addendum No. 1 for the Village of Pleasantville – Walnut Street Tank Improvements. Submit questions in writing to Verdantas, c/o Alan Brown, PE.

Bidder

Date



Engineer

August 27, 2026
Date

END OF ADDENDUM NO. 1