



To: All Plan Holders of Record

From: Verdantas LLC
For the Owner

Re: *Addendum No. 1*
Wakefield Road Sanitary Pump Station Improvements
Village of Hiram, OH

Date: March 23, 2026

This Addendum forms a part of the contract documents and modifies the original bidding documents dated March 2026 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

QUESTIONS AND ANSWERS

Q1. Are other pump manufacturers acceptable?

A1. No alterations to Section 432139 Subsection 2.2 will be made. A review will occur after award of the bid of any requested approved equals.

Q2. We do not see a Geotechnical Report in the specification book for Hiram – Wakefield Road Sanitary Pump Station Improvements bid.

A2. No Geotechnical study was performed as part of this project.

Q3. Can we visit site anytime? Or do we need to contact someone for site visit?

A3. The site is not fenced in and is accessible for a site visit.

PLANS

1. Plan Sheet 8 of 12, “BYPASS VAULT” detail, **Add** an additional 4-inch plug valve to the upstream side of the “4” DIP SANITARY WYE FL“. Shift the proposed “4” FLANGE ADAPTER” between the new 4-inch plug valve and 4-inch sanitary wye to 6” off the proposed bypass vault wall.

RS:mep

Enclosures

Z:\Project Files\GA-HZ\Hiram\32644 - Hiram Wakefield LS Improvements\Working\Bid Documents\Addendum\Addendum 01\Addendum 01.Doc