



To: All Plan Holders of Record

From: Verdantas LLC
For the Owner

Re: *Addendum No. 1*
Erskine Avenue Crossing Improvements
Boardman Township, OH

Date: June 9, 2026

This Addendum forms a part of the contract documents and modifies the original bidding documents dated May 2026 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

QUESTIONS AND ANSWERS

Q1. Will precast be an option for the junction chambers in lieu of the cast in place?

A1. Yes, precast chambers can be used in lieu of cast-in-place, so long as all other criteria are met in terms of PE stamp, delegated structural design, dimensions, roadway loadings, etc as stated on the plans and specs. Any changes to quantities of bid items or other additional ancillary improvements resulting from such a proposed change must be included in the cost of the chamber at the time of bid.

MD:mg

Z:\Project Files\AA-BZ\Abewater\39498 - Erskine Crossing Improvements\Working\Bid Documents\Addenda\Addendum 01\Addendum 01.Doc