



To: All Plan Holders of Record

From: Verdantas LLC  
For the Owner

**Re: Addendum No. 1**  
**Old Main Street Bridge Improvements Booster Pump Station Replacement - Phase II**  
**City of Conneaut, OH**

Date: March 6, 2026

This Addendum forms a part of the contract documents and modifies the original bidding documents dated February 2026 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

### **QUESTIONS AND ANSWERS**

Q1. Did the Engineer work with any specific temporary bypass pump companies on this project?

**A1. No.**

Q2. Does the temporary bypass pump need to be NSF certified?

**A2. Yes.**

Q3. Will the temporary bypass system, pump and piping, need disinfected and tested?

**A3. The temporary bypass system, pump, and piping is required to be disinfected and bacterial tested.**

Q4. What is the suction pressure and discharge pressure on the existing station?

**A4. The pressures that the pump station experiences are as follows;**

**Suction Minimum Pressure: 78 psi**

**Suction Maximum Pressure: 88 psi**

**Discharge Minimum Pressure: 88.5 psi**

**Discharge Maximum Pressure: 91 psi**

Q5. What are the extents of demolition of the existing masonry?

**A5. The masonry below the 8 foot line is existing and shall remain. New masonry above 8 feet shall be provided as shown in the section on Sheet 15 of the contract drawings.**

Q6. Is it possible to schedule a tour of the existing booster station.

**A6. Please contact Caleb Rzeszutek at (440) 593-7435 or [waterdist@conneautoh.org](mailto:waterdist@conneautoh.org)**

RS:mep

Z:\Project Files\CA-DZ\Conneaut\41632 - Conneaut OH Old Main Street BPS & Water\Working\Bid Documents\Ph 2 - Booster Pump Station\Addenda\Addendum 01\Addendum 01.Doc