



To: All Plan Holders of Record

From: Verdantas LLC
For the Owner

Re: *Addendum No. 1*
Sanitary Siphon Replacement Project
Village of Lowellville, OH

Date: March 10, 2026

This Addendum forms a part of the contract documents and modifies the original bidding documents dated February 2026 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

GENERAL

The Village of Lowellville has not yet received the RR Permit in order to understand the conditions and requirements for such elements as insurances and flagging. The Contract will not be awarded until the permit is in hand and understood by the Village.

PRE-BID CONFERENCE

Attached is the Sign-In Sheet.

SPECIFICATIONS

In Specification Section 432129 – Submersible Pumps: **Delete** Part 2.4 SPARE PARTS

PLANS

1. Sheets 10 and 11 – The proposed mixer unit can be connected within the proposed PCP. The Contractor will need to ensure the PCP has adequate space to accommodate the mixer's electrical components. The mixer unit will need to be connected to a lockout preventing the mixer from operating during pump-on cycles.
2. Sheets 15 and 16 – McGaffney Road was not intended to be totally closed in order to construct this project. This road is a federal aid route for the Village of Lowellville connecting US 224 to the center of the Village. If road closures are needed to occur then the contractor will need to submit a written plan to the Village for their review and approval 2-weeks prior to the intended closure.
3. Sheet 20 Plan and Section Views – Float cord bracket will be positioned in the field so that the floats are not impacted by the action of the mixer unit.

CK/LM:mep

Enclosure

H:\2021\210340\SPEC\Addenda\Addendum 01\Addendum 01.Doc



MEETING SIGN-IN: Village of Lowellville
 Sanitary Siphon Replacement Project
 ARC Funded Project, OPWC Funded Project No. CF26Y
 USEPA Community Grants Program Funding, WPCLF Funded Project
 DATE: March 9, 2026 10:30 am
 Project Number: 210340

NAME	COMPANY (REPRESENTING)	ADDRESS	CITY	ZIP	EMAIL ADDRESS
Jim Tressa	Rudzik Exc.	401 Lowellville Rd	Stuthers	44471	Jim@RudzikExcavating.com
Liam Gatesman	Marcucci/Garney	18 Hague St	Youngstown	44502	Liam@MarcucciGarney.com
Esther Parks	"See" Duxbury Electric	186 W. South Ave	Norwalk, Ohio	44452	eparks@duxburyelectric.com
Cody BoVA	J.S. BOVA	235 STATE ST.	STATHOLE	44471	Cody@JSBOVA.COM
Joe De Santis	Pump Systems			44514	Jdesantis@pumpsystemsllc.com
Dave Chepke	Utility Cont.	321 S. Meridian	Yo.	44509	utilitycontracting@att.net
James Harrison	EDG				JHarrison@ENV
Paul Durbia	Lowellville Village				Design group.com
Joann Bonarino	Lowellville Adm.				
Moussa BITTAR	S.E.T., Inc.	235 E. Waterst. Lowellville, OH 44436			bidding@setinc.biz