



To: All Plan Holders of Record

From: Verdantas LLC
For the Owner

Re: *Addendum No. 2*
Sanitary Siphon Replacement Project
Village of Lowellville, OH

Date: March 10, 2026

This Addendum forms a part of the contract documents and modifies the original bidding documents dated February 2026 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

GENERAL

The proposal items – Not a Bid Form.xlsx spreadsheet posted to the web has been updated.

PLANS

Sheets 16 and 17 – The Boring Entry Pit shall be 35' Long by 10' Wide, with the Receiving Pit being 10' by 10'. For Ref. No. 10, 20 Inch Steel Pipe Encasement, Bored or Jacked, the Contractor shall include the cost of any impacted buried utility (Water and/or Sanitary), any utility bypass, temporary support and/or relocation.

CK/LM:mep

Enclosures

H:\2021\210340\SPEC\Addenda\Addendum 02\Addendum 02.Doc