



NOTES:

1. STANDARD METERS SHALL BE 5/8" X 3/4" SERVICE METERS AS OUTLINED WITHIN SPECIFICATIONS.
2. CONTRACTOR SHALL PROVIDE INSERT STIFFENERS AT ALL POINTS OF CONNECTION OF PE SERVICE LINE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
3. PIT ASSEMBLY SHALL BE SUPPORTED ON 2 OR MORE 1/2" x 8" x 16" CONCRETE PAVERS POSITIONED BELOW CONNECTIONS TO STABILIZE ASSEMBLY AND CONNECTIONS.
4. 3/4" CTS PE (PEP) SERVICE LINE SHALL BE UTILIZED.

METER PIT INSTALLATION
SCALE: NOT TO SCALE



ISSUE DATE:	3/28/24
SCALE:	NOT TO SCALE
DESIGNED BY:	BRA
DRAWN BY:	AGD
CHECKED BY:	BRA

**VILLAGE OF SOUTH SOLON
WATER METER IMPROVEMENTS
MADISON COUNTY, OHIO**

METER PIT DETAIL

PROJECT NO.	
220924	
DISCIPLINE	
CIVIL	
SHEET	OF
1	1