

Addendum No. 3

Date	June 3, 2025
To	Bidders
From	James G. Golias II, PE
Subject	City of Crossville 2024 SPEC Building (PO 16174)
Project Number	Verdantas No. 232137 / Agency Tracking No. 330001-00425

Receipt of this addendum must be acknowledged and noted in accordance with the Contract Documents and Specifications. Failure of any bidder to receive any such addendum or interpretation shall not relieve such bidder from any obligation under his/her bid as submitted. All addenda so issued shall become part of the contract documents.

Additional Bidder Questions and Responses:

1. The drawings don't show any switching for the interior lighting, will this be done with breakers or switches and if it's switches where would they be located and in how many locations would they want them?
 - a. **Contractor to provide one switch per circuit and locate at panel.**
2. The wall packs are shown controlled by photocell, are they expecting 2 different photocells since there are 2 different circuits or a contactor to control both circuits at the same time?
 - a. **Contractor to provide a photocell for each circuit.**

Clarification to previous Addendum Question:

1. Insulation must meet all thermal conformance IECC 2018 requirements (i.e. R-Value, U-Factor, etc.).

END OF ADDENDUM NO. 3