



To: All Plan Holders of Record

From: Verdantas LLC
For the Owner

Re: Addendum No. 5
Ridge Road (S.R. 84) Slope Stabilization
City of Willoughby

Date: September 16, 2025

This Addendum forms a part of the contract documents and modifies the original bidding documents dated August 2025 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

QUESTIONS AND ANSWERS

Q1. Will the use of temporary portable traffic signals be allowable for this project?

A1. Maintenance of Traffic (MOT) is addressed by the General Notes on Sheet 2/12 of the project drawings. Per those notes:

- Ridge Road will be closed to local traffic, and that local traffic will be detoured.
- The contractor is required to submit detour plans to the City for review.
- Signing and other traffic controls are included in the list of safeguards that may be used to detour traffic and control access during construction
- Payment for all traffic control devices and all work associated with ODOT Item 614 will be a lump sum (Bid Form BF.9 - Ref. No. 23 - Maintaining Traffic, As Per Plan).

Portable traffic signals are “traffic controls” and therefore allowable under Item 614, pending review by the City. All costs associated with them should be included in the Ref. No. 23 - Maintaining Traffic, As Per Plan item.

MS/JB/TL:mep

Enclosures

H:\2024\240113501\SPEC\Addenda\Addendum 05\Addendum 05.Doc